



QUALITY CONTROL DISTRICT LABORATORY
KERALA WATER AUTHORITY
CANTONMENT P O, KOLLAM - 691 001

☎0474 2994773

✉qedlkollam@gmail.com

Test Report

Report No: 2024/QCDKLM/4202	Date of Issue: 03/10/2024
Customer Name & Address:	1. Date of Receipt: 30/09/2024
SIDDHARTHA CENTRAL SCHOOL AMBALAMKUNNU, NETTAYAMP.O, AYUR, KOLLAM - 691 537 8606647764	2. Sampling done by: Health Inspector, Primary Health Centre, Elamadu, Department of Health Service, Government of Kerala
	3. Sample Code: 2024/QCDKLM/4202
	4. Source of Sample: Well Water
	5. Sample Description: Drinking water
	6. Sample Quantity: 250 ml
	7. Test Performing Dates From: 30/09/2024 To: 03/10/2024

Sl. No.	Characteristics	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Total Coliforms/ 100 ml	IS 15185 : 2016	Shall not be detected/ 100 ml	ABSENT
2	E. coli /100 ml	IS 15185 : 2016	Shall not be detected/ 100 ml	ABSENT

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Verified By <u>Remya</u> Remya Krishnan S Bacteriologist 2	* End of Report *	Authorized By <u>Chithra R</u> BACTERIOLOGIST QUALITY CONTROL DISTRICT LAB KERALA WATER AUTHORITY KOLLAM
--	-------------------	--

KWA/KLM/R/19

Issue No. 01

Issue Date: 06.01.2024

Rev. No. 01

Rev. Date: 21.08.2024